Fire, Building & Life Safety Division Certificate of Occupancy Fire Prevention Checklist Category: Construction PAGE 1 of 1 Revised: 1/1/2009 Code Reference: 2006 IFC Chapter 9 & 10

NOTE: THIS CHECKLIST IS ALSO IN THE FORMS SECTIONS

Purpose: This checklist was developed to provide assistance by documenting the most common items that will be confirmed as being in compliance for Temporary Certificate of Occupancy (TCO) or Full Certificate of Occupancy (C of O). The checklist is not intended to include all items or issues. Based on the occupancy use, compliance with additional items may be required prior to the Goodyear Fire Department signing for full C of O.

	<u>Yes</u>	<u>No</u>	N/A
Temporary C of O			
Fire sprinkler system inspected, tested and approved (green tagged).			
Fire alarm system inspected, tested and approved (green tagged).			
Full C of O			
<u>Exterior</u>			
Fire riser room door marked FIRE RISER?			
Fire alarm control panel door marked FACP?			
Fire lane signs posted and approved?			
Building address posted?			
Suite numbers posted, front and rear doors?			
FDC identified with signage, if required?			
FDC visible and accessible?			
Knox box installed in accordance with Policy P506?			
Keys provided for placement in Knox box(s)?			
Is gas meter subject to vehicle collision? If yes, bollards are required.			
<u>Interior</u>			
Fire sprinkler system inspected, tested and approved?			
Fire alarm system inspected, tested and approved?			
Hood system inspected, tested and approved?			
Fire extinguishers installed to be visible and accessible?			