NUMBER	ITEMS	NOT REQ'D	NOT DONE	SATISFIED	DRYWELLS REVIEW # BY / DATE Location in Standards

	Design & Plan Requirements				
1	Review General & Grading checklists	☐	☐	☐	See web site (General) (Grading)
2	Drywells not allowed within ¼ mile of a positive gravity outlet (SD or canal)	☐	☐	☐	3.3.6(C.8.c)
3	Drywells not allowed for projects that require a dry well aquifer protection permit from ADEQ (gas stations, loading docks)	☐	☐	☐	3.3.6 (G.2)
4	Drywells not allowed in R/W or PUE	☐	☐	☐	3.3.6(G.4h)
5	Drywells are required if basin is > 1' deep	☐	☐	☐	3.3.6(C.1.f)
6	Provide enough drywells so basin will percolate within 36hrs	☐	☐	☐	3.3.6(C.8), 3.3.6(G.4.i), 3.3.6(G.4.k)
7	Use Maxwell Type IV or Maxwell Plus	☐	☐	☐	3.3.6(G.4.a)
8	16' min separation from Maxwell IV to Maxwell Plus	☐	☐	☐	Per Torrent
9	Min 20' from outlet, 100' from other drywells (show dims on plans)	☐	☐	☐	3.3.6(G.4.g), ADEQ COAC #05-2379 WS
10	0.5' grate elevation from bottom of basin.	☐	☐	☐	3.3.6(G.4.d)
11	Locate next to the basin sides, not in sump of basin (to create a bottom without humps so the basin is useable)	☐	☐	☐	3.3.6(G.4.i)
12	In pavement OK if piped from basin (Sealed water tight grate/cover in pavement areas)	☐	☐	☐	3.3.6(G.4.e), 3.3.6 (G.4.f)
13	Identification number shall be on grading/site plan next to each drywell (HTE xx-xxxx-A,B,C)	☐	☐	☐	
14	Drywells shall be tied down with Lat & Long (Either leader to well or in a table)	☐	☐	☐	
15	"Drywell Notes" shall be on plan set	☐	☐	☐	
16	Existing projects shall submit a "Drywell site plan" Current projects under review shall have the above requirements on the grading plans.	☐	☐	☐	

Revised 6/5/2008

NUMBER	ITEMS	NOT REQ'D	NOT DONE	SATISFIED	DRYWELLS REVIEW #			
					BY		DATE	
					Location in Standards			
17	100' from a City Well Site	☐	☐	☐				
18	50' from Subdivision property line	☐	☐	☐	un-developed side			
19		☐	☐	☐				
	ADEQ materials to be submitted							
1	Copy of ADEQ Drywell Registration form, in section "F" Owners Identification name or number, provide number beginning with application HTE xx-xxxx-A, B, C	☐	☐	☐	3.3.6(G.3.c), 3.3.6(G.5.b)			
2	ADEQ "Annual Dry wells Inspection checklist" (Maintenance plan) shall be provided	☐	☐	☐	3.3.6(G.3.b), 3.3.6(G.5.c)			
3		☐	☐	☐				
	Permitting & Review Fees							
1	No plan review fees for existing retro fit projects	☐	☐	☐				
2	Inspection Permit fee: $150 for each Drywell under other grading, for both current and retrofit	☐	☐	☐				
3		☐	☐	☐				
	Post Plan approval							
1	Label folder with QS, project name and HTE for filing.	☐	☐	☐				
2	A copy of the completed ADEQ registration will be needed prior to acceptance of As-Builts. As-Builts shall reflect constructed location. Lat & Long/dimension shall be revised to indicate constructed location	☐	☐	☐				
3		☐	☐	☐				

Revised 6/5/2008