

FINISHED GRADE

SECURE BALLMARKER WITH  
2 STRIPS DUCT TAPE OR WIRE

36"

#4 REBAR

BEDDING

WATER PIPE

12"

NOTES:

1. CONTRACTOR IS TO INSTALL, ACTIVATE, AND PROGRAM MARKER BALL WITH SIZE OF MAIN, MATERIAL OF MAIN, AND THE TYPE OF FITTING.

